

WATER REGULATIONS ADVISORY SCHEME

BS6920 TEST ON EFFECT OF WATER QUALITY

FINAL REPORT

Organisation : C.I.C.E.

Product : Enamel

WRc-NSF REPORT No: MAT/LAB 221F

Date of Report 09/05/02

WORK/MAT012

Revision No. 10, 19/05/01

Page 1 of 6

WRc-NSF Ltd, Hanley Road, Medmenham, Marlow, Bucks SL7 2HD, UK
Tel: +44 (0) 1491 636500 Fax: +44 (0) 1491 636501

WRc-NSF Ltd. Registered in England No. 3754780.
Registered Office: Frankland Road, Blagrove, Swindon, Wiltshire SN5 8YF, England.



WRc-NSF Ltd
a joint venture of
WRc plc and
NSF International

WRC-NSF Final Report for the Testing of a Product for Water Regulations Advisory Scheme Approval	WRC-NSF Report No	MAT/LAB 221F
Name of Organisation: C.I.C.E.		
Product: Enamel	Date of Report	09/05/02

1. SUMMARY

Test	Result
Odour and flavour of water	Not applicable
Appearance of water	Not applicable
Growth of aquatic microorganisms	Not applicable
The extraction of substances that may be of concern to public health	Not applicable
Extraction of metals	Pass

This product has satisfied the criteria set out in BS6920: Part 1: Clause 8, extraction of metals: 2000 "Specification" and thus does comply with the requirements of the Water Regulations Advisory Scheme Tests of Effect on Water Quality and is suitable for use with hot (up to 85 °C) and cold water. No other tests were undertaken on this product.

Mark Norris
Mr Mark Norris, Materials Test Manager Date 10th May 2002

Please note the following statements
a) The samples of the product referred to in this report have been tested in accordance with the methods specified in BS6920: 2000 Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water.
b) This work has been undertaken in the UKAS accredited laboratory of WRC-NSF Ltd Medmenham, UKAS registration number 1550, unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.
c) The results specified in this report relate only to the samples(s) of this product submitted for testing. Any changes in the nature or source of ingredients and the process of manufacturer or application could affect the suitability of this product for use in contact with potable water.
d) We draw to your attention that reports issued by the accredited test laboratories do not of themselves constitute approval by the Water Regulations Advisory Scheme or the test laboratory. Only a letter from the Scheme, citing a Directory Reference number can be regarded as indicating approval.
e) Materials and products intended for use by a public water supply company in the preparation or conveyance of water may need to satisfy more comprehensive toxicological requirements as specified by the Drinking Water Inspectorate. These additional requirements are necessary to ensure Water Company usage complies with Regulation 25 of the Water Supply (Water Quality) Regulations 1989.